



WATER DEPARTMENT NOVEMBER 2019 MONTHLY REPORT

| | |
|-------------------------------------|--------------------|
| <u>Water Supplied this month</u> | 5,909,300 gallons |
| <u>Average Daily Water Supplied</u> | 196,977 gallons |
| <u>Water produced Y.T.D -</u> | 98,912,600 gallons |

Water and Sewer Inspections

None this month

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

132 Waterside Dr. – 2 meters/ 1 mxu
12 Waterside Dr. – 2meters/1 mxu
8 Waterside Dr. – 2 meters/1 mxu
305 Edgewood St. – 1 mxu
102 Jacobs ave. – 1 mxu
30 Royalview Dr. – 1 mxu
6 Church St. – 1 meter

Final Readings

110 Jacobs Ave.
69 Champions Dr.
108 Wills Island
47 Champions Dr.
93 Champions Dr.
139 Waterside Dr.
3 waterside Dr.

C.O. Inspections


69 Champions Dr.
47 Champions Dr.
93 Champions Dr.
3 Waterside Dr.

Meters removed : 0

Service Calls : 19

Shut-offs : 4

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did various Miss Utility locate tickets.
7. Collected more data for Rob (DBF) for allocation permit.
8. Turned in copies of O.D.W. paperwork for Lead and Copper sampling to Town manager.
9. Looked over new lift station prints, help mark out location at WWTP.
10. Helped Bayside fire flow test hydrants on Market St. for Mkt. St. Appts.
11. Replaced check valves on Neptunr pump at well 6.
12. Teider Electric replaced co-axe cable at well 6.
13. Replaced UPS at well 2.
14. Purchased new block heater for generator at well 2.



Scott Kimball, Superintendent

Water Department