



TOWN OF BRIDGEVILLE

WWTP Monthly Report for November 2019

Date: December 5, 2019

Superintendents Report

- 1. All reports and testing are being completed**
- 2. Phillip Mowbray attended harassment class**
- 3. Patrick Rankin attended Harassment Webinar**
- 4. Grass cutter knocked off Manhole cover at sonic lift station Phil and I put it back on**
- 5. Cleared locate ticket on Redden Rd**
- 6. Marked out where County Lift Station will be placed**
- 7. Cleared locate with UCLS**
- 8. Set up date with DNREC foe CSI which will be December 13th**
- 9. Reviewed plans for 7-11**
- 10. Force main break in Greenwood underneath County Library. Sussex County and Clean Delaware Hauled approximately 16 load of sewer to the treatment plant. 11/26 – 11/29/19**
- 11. Greenwoods monthly flow numbers for November appear to be correct. They must have been metering flow from pumpers and bypass pump.**

Respectfully Submitted,

A handwritten signature in black ink that reads "Patrick J. Rankin". The signature is written in a cursive style with a large, stylized initial "P".

Patrick Rankin
Wastewater Superintendent