



TOWN OF BRIDGEVILLE

WWTP Monthly Report for December 2019

Date: January 9, 2020

Superintendents Report

- 1. All reports and testing are being completed**
- 2. Comminuter (A) down and out for repair**
- 3. #2 spray rig main power line splice is bad tripping main breaker. Repair has been scheduled**
- 4. DNREC annual inspection. No non-compliances to my knowledge**
- 5. Performed annual Pretreatment inspection at Simmons Feed and RAPA.**
- 6. Back flushed Raw Pump (A)**
- 7. Clean Delaware pumped 11,000 gal off of digester**

Respectfully Submitted,

Patrick J. Rankin

A handwritten signature in black ink that reads "Patrick J. Rankin".

Wastewater Superintendent

TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT
DECEMBER, 2019
DATE: JANUARY 9, 2020

BRIDGEVILLE		GREENWOOD
295,000	MAXIMUM AVERAGE TOTAL	61,129
231,000		51,734
7,161,000		1,603,771

TOTAL COMBINED FLOW = 8,764,771
GREENWOOD'S PERCENTAGE OF FLOW = 23.33%

NPDES PERMIT REPORT

TOTAL DAYS STREAM DISCHARGE = 0

AVERAGE DAILY STREAM FLOW = 0

TOTAL STREAM DISCHARGE = 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS DISCHARGE TO LAGOON = 31

AVERAGE DAILY FLOW TO LAGOON = 231,000

TOTAL FLOW DISCHARGE TO LAGOON = 7,161,000

TOTAL DAYS IRRIGATED = 0

TOTAL GALLONS SPRAYED ON FIELD = 0

TOAL SPRAY VIOLATIONS = 0