



## **TOWN OF BRIDGEVILLE**

### **WWTP Monthly Report for January 2020**

**Date: February 4, 2020**

#### **Superintendents Report**

- 1. All reports and testing are being completed**
- 2. 2 leaks in force main going to lagoon – switched over to stream discharge. Hopkins Const. ordered bands for repair 3 weeks to get here.**
- 3. Contacted soil conservation about exposed piping by outfall 100**
- 4. Main electrical line to Spray rig 2 had to be repaired**
- 5. Replaced center drive on Spray rig 1**
- 6. Comminutor A back in and running**
- 7. Wrote two Non-Compliance letters to DNREC for permit violation on BOD5**
- 8. DNREC took a split sample of stream Effluent**
- 9. Blockage 103 Sussex Ave cleared blockage and repaired cleanout**
- 10. Installed new effluent flow meter**

**Respectfully Submitted,**

**Patrick J. Rankin**

A handwritten signature in black ink that reads "Patrick J. Rankin".

**Wastewater Superintendent**

# TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT

**JANUARY, 2019**

**DATE: FEBRUARY 4, 2020**

BRIDGEVILLE		GREENWOOD
362,000	MAXIMUM AVERAGE TOTAL	68,705
235,650		54,214
7,305,000		1,762,088

TOTAL COMBINED FLOW = 9,067,088  
GREENWOOD'S PERCENTAGE OF FLOW = 24.12%

## NPDES PERMIT REPORT

TOTAL DAYS STREAM DISCHARGE = 23

AVERAGE DAILY STREAM FLOW = 228,086

TOTAL STREAM DISCHARGE = 5,246,000

## SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS DISCHARGE TO LAGOON = 9

AVERAGE DAILY FLOW TO LAGOON = 228,777

TOTAL FLOW DISCHARGE TO LAGOON = 2,059,000

TOTAL DAYS IRRIGATED = 9

TOTAL GALLONS SPRAYED ON FIELD = 4,170,000

TOAL SPRAY VIOLATIONS = 0