



TOWN OF BRIDGEVILLE

WWTP Monthly Report for July 2020

Date: August 7, 2020

Superintendents Report

- 1. All reports and testing are being completed**
- 2. Zack Construction at plant looking a Demo process**
- 3. Field Net down on Rig #1**
- 4. Fueled plant rental Gen and Heritage shores Gen**
- 5. Effluent Pump A is being repaired**

Respectfully Submitted,

Patrick J. Rankin

A handwritten signature in black ink that reads "Patrick J. Rankin". The signature is written in a cursive style with a large, stylized initial "P".

Wastewater Superintendent

TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT JULY 2020

DATE: AUGUST 7, 2020

BRIDGEVILLE		GREENWOOD
642,000	MAXIMUM AVERAGE TOTAL	96,961
307,450		58,598
9,531,000		1,816,556

TOTAL COMBINED FLOW = 11,347,556
GREENWOOD'S PERCENTAGE OF FLOW = 19.06 %

NPDES PERMIT REPORT

TOTAL DAYS STREAM DISCHARGE = 0

AVERAGE DAILY STREAM FLOW = 0

TOTAL STREAM DISCHARGE = 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS DISCHARGE TO LAGOON = 30

AVERAGE DAILY FLOW TO LAGOON = 307,450

TOTAL FLOW DISCHARGE TO LAGOON = 9,531,000

TOTAL DAYS IRRIGATED = 3

TOTAL GALLONS SPRAYED ON FIELD = 916,000

TOTAL SPRAY VIOLATIONS = 0