



TOWN OF BRIDGEVILLE

WWTP Monthly Report for SEPTEMBER 2020

Date: OCTOBER 8, 2020

Superintendents Report

- 1. All reports and testing are being completed**
- 2. Zacks construction put down crushed concrete for crane**
- 3. Zacks construction set up crane**
- 4. Took Vegetation grab sample at spray field/ soybeans**
- 5. Raw pump A and B both rebuilt and back in service**
- 6. Heritage shores lift station pump 1 had to be pulled and debris taken out of pump. Back in service and working well**
- 7. Changed batteries and put battery tender on Heritage Shores Generator.**
- 8. Generator installed at plant**
- 9. Zacks Construction started driving sheets in ground for dewatering process.**
- 10. Putting sheets in were put on hold until water line deaden.**

Respectfully Submitted,

A handwritten signature in black ink that reads "Patrick J. Rankin". The signature is written in a cursive style with a large initial "P".

Patrick J. Rankin

Wastewater Superintendent

TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT

SEPTEMBER 2020

DATE: OCTOBER 8, 2020

BRIDGEVILLE		GREENWOOD
828,000	MAXIMUM AVERAGE TOTAL	172,364
353,800		76,579
10,614,000		2,297,377

TOTAL COMBINED FLOW = 12,911,377
GREENWOOD'S PERCENTAGE OF FLOW = 21.64 %

NPDES PERMIT REPORT

TOTAL DAYS STREAM DISCHARGE = 0

AVERAGE DAILY STREAM FLOW = 0

TOTAL STREAM DISCHARGE = 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS DISCHARGE TO LAGOON = 30

AVERAGE DAILY FLOW TO LAGOON = 353,800

TOTAL FLOW DISCHARGE TO LAGOON = 10,614,000

TOTAL DAYS IRRIGATED = 16

TOTAL GALLONS SPRAYED ON FIELD = 10,395,000

TOAL SPRAY VIOLATIONS = 0