



TOWN OF BRIDGEVILLE

WWTP Monthly Report for November 2020

Date: December 11, 2020

Superintendents Report

- 1. All reports and testing are being completed**
- 2. Pulled #1 pump at Heritage shores lift station – cleared debris from pump**
- 3. Cleared locate tickets**
- 4. Air compressors serviced**

Respectfully Submitted,

A handwritten signature in black ink that reads "Patrick Rankin". The signature is stylized with a large, sweeping initial "P".

Patrick Rankin

Wastewater Superintendent

TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT

NOVEMBER, 2020

DATE: DECEMBER 11, 2020

BRIDGEVILLE		GREENWOOD
650,00	MAXIMUM AVERAGE TOTAL	164,299
415,300		87,519
12,459,00		2,646,063

TOTAL COMBINED FLOW = 15,105,063
GREENWOOD'S PERCENTAGE OF FLOW = 21.24%

NPDES PERMIT REPORT

TOTAL DAYS STREAM DISCHARGE = 0

AVERAGE DAILY STREAM FLOW = 0

TOTAL STREAM DISCHARGE = 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS DISCHARGE TO LAGOON = 30

AVERAGE DAILY FLOW TO LAGOON = 415,300

TOTAL FLOW DISCHARGE TO LAGOON = 12,459,000

TOTAL DAYS IRRIGATED = 11

TOTAL GALLONS SPRAYED ON FIELD = 5,456,000

TOAL SPRAY VIOLATIONS = 0