



TOWN OF BRIDGEVILLE

WWTP Monthly Report for January 2021

Date: February 8, 2021

Superintendents Report

- 1. All reports and testing are being completed**
- 2. 74 Champions Drive sewer odor in house – Dry P-Trap**
- 3. Internet down due to Const. Crew hit cable**
- 4. Phillip returned to work**
- 5. No longer receiving flow from Heritage shores lift station – being pumped to Seaford WWTP**
- 6. Phillip did preventive maintenance for the month**
- 7. Sent Rob Duma DBF pretreatment paperwork for end of year report**

Respectfully Submitted,

Patrick J. Rankin

A handwritten signature in black ink that reads "Patrick J. Rankin". The signature is written in a cursive style with a large initial "P".

Wastewater Superintendent

TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT

JANUARY, 2021

DATE: FEBRUARY 8, 2021

BRIDGEVILLE		GREENWOOD
391,000	MAXIMUM AVERAGE TOTAL	105,261
247,160		66,492
7,662,000		2,061,256

TOTAL COMBINED FLOW = 9,723,256
GREENWOOD'S PERCENTAGE OF FLOW = 26.9%

NPDES PERMIT REPORT

TOTAL DAYS STREAM DISCHARGE = 0

AVERAGE DAILY STREAM FLOW = 0

TOTAL STREAM DISCHARGE = 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS DISCHARGE TO LAGOON = 31

AVERAGE DAILY FLOW TO LAGOON = 247,160

TOTAL FLOW DISCHARGE TO LAGOON = 7,662,000

TOTAL DAYS IRRIGATED = 14

TOTAL GALLONS SPRAYED ON FIELD = 4,170,000

TOAL SPRAY VIOLATIONS = 0