



TOWN OF BRIDGEVILLE

WWTP Monthly Report for March 2021

Date: April 9, 2021

Superintendents Report

- 1. All reports and testing are being completed**
- 2. Jeffs Package store blockage – camera line several time lateral to main needs to be repaired or replaced**
- 3. Located ARV's with Phil M. and Ed L. on 16" F/M checking condition all valves need replacing**
- 4. George and Lynch working for Town through Sussex County Time and Material contract**
- 5. Sussex County Lift Station almost complete.**

Respectfully Submitted,

Patrick J. Rankin

A handwritten signature in black ink that reads "Patrick J. Rankin". The signature is stylized with a large, sweeping initial "P".

Wastewater Superintendent

TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT

MARCH 2021

DATE: APRIL 9, 2021

BRIDGEVILLE		GREENWOOD
399,000	MAXIMUM AVERAGE TOTAL	123,622
276,670		79,470
8,300,000		2,462,856

TOTAL COMBINED FLOW = 10,762,856
GREENWOOD'S PERCENTAGE OF FLOW = 29.67 %

NPDES PERMIT REPORT

TOTAL DAYS STREAM DISCHARGE = 0

AVERAGE DAILY STREAM FLOW = 0

TOTAL STREAM DISCHARGE = 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS DISCHARGE TO LAGOON = 31

AVERAGE DAILY FLOW TO LAGOON = 276,670

TOTAL FLOW DISCHARGE TO LAGOON = 8,300,000

TOTAL DAYS IRRIGATED = 17

TOTAL GALLONS SPRAYED ON FIELD = 7,329,000

TOAL SPRAY VIOLATIONS = 0