



TOWN OF BRIDGEVILLE

WWTP Monthly Report for April 2021

Date: May 7, 2021

Superintendents Report

- 1. All reports and testing are being completed**
- 2. Pump station 431 start up and flowing to seaford**
- 3. Shut off RBC A side and pumped down**
- 4. All raw influent flow now going to Seaford's WWTP**
- 5. Comminutor A repaired**

Respectfully Submitted,

Patrick J. Rankin

A handwritten signature in black ink that reads "Patrick J. Rankin".

Wastewater Superintendent

TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT APRIL 2021

DATE: MAY 7, 2021

BRIDGEVILLE		GREENWOOD
255,000	MAXIMUM AVERAGE TOTAL	
133,000		
3,857,000		

TOTAL COMBINED FLOW = 10,812,998
GREENWOOD'S PERCENTAGE OF FLOW =

NPDES PERMIT REPORT

TOTAL DAYS STREAM DISCHARGE = 0

AVERAGE DAILY STREAM FLOW = 0

TOTAL STREAM DISCHARGE = 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS DISCHARGE TO LAGOON = 30

AVERAGE DAILY FLOW TO LAGOON = 133,000

TOTAL FLOW DISCHARGE TO LAGOON = 3857,000

TOTAL DAYS IRRIGATED = 19

TOTAL GALLONS SPRAYED ON FIELD = 7,592,000

TOAL SPRAY VIOLATIONS = 0