



Applicant Name: GED S. Main Dist, LLC (Gary Krupnick/gpk33fly@aol.com/631-435-1818) 2nd Review

Contact Person: Axiom Engineering, LLC (Ken Christenbury/ken@axeng.com/302-855-0810)

Project Title/Name: PODS of Bridgeville (S Main Street/po 131-15.00-1.00)

*Note: Item numbers with a * are only required to provide general information at the Preliminary Development Plan stage.*

Item #	Required Information [per §234-22A(7)]	In Compliance	Not in Compliance
Plat Information			
1.	Name and address of owner and applicant.	X	
2.	Subdivision name. <i>See also §234-56D.</i>	X	
3.	Signature and seal of a registered Delaware land surveyor or professional engineer.	X	
4.	Name, signature, license number, seal, and address of engineer, land surveyor, architect, planner, and/or landscape architect, as applicable, involved in preparation of plat.	X	
5.	Title block denoting type of application, Tax Map sheet, county, municipality, block, lot, and street location.	X	
6.	A vicinity map at specified scale showing location of tract with reference to surrounding properties, streets, municipal boundaries, etc. within 500 feet.	X	
7.	Date of current survey.	X	
8.	Schedule of required and provided zoning district standards, including lot area, width, depth, yard, setbacks, building coverage, open space, parking, etc. <i>See also §§ 234-30C, 31C, 32C, 33C, 34C, 37, 39C, 40C, 41C, 44 & Article XII.</i>		X*
9.	North arrow and scale.	X	
10.	Acreage of tract to nearest tenth of an acre.	X	
11.	Date of original and all revisions.	X	
12.	Size and location of existing or proposed structures with all setbacks dimensioned. <i>See also §§234-30C, 31C, 32C, 33C, 34C, 37, 39C, 40C, 41C, 44 & Article XII.</i>	X	
13.	Proposed lot lines and areas of lots in square feet. <i>See also §234-57.</i>	X	
14.	Locations and dimensions of existing and proposed streets.	X	
15.	Copy and/or delineation of existing deed restrictions or covenants.		N/A
16.*	Copies of and a summary of deed restrictions for the new subdivision, including agreements for the operation and maintenance by the property owners or agency in the subdivision of common areas, open space, recreation facilities, surface drainage facilities, erosion and sedimentation control facilities, water supply facilities, sanitary sewer facilities, forested buffer strips, or other improvements deemed necessary by the Planning and Zoning Commission.		N/A
17.	Existing or proposed easement or land either reserved for or dedicated to public use for the residents of the proposed development.	X	
18.*	Development or staging plans.	X	
19.	List of required regulatory approvals or permits.		Previously Submitted
20.	Variances requested. <i>See also §234-23.</i>		None Requested
21.	Payment of application fees.		Per Town
Setting – Environmental Information			
22.	Property owners and lines of all parcels within 200 feet identified on most recent Tax Parcel Map.	X	
23.	Land used primarily for agricultural purposes, lands in Agricultural Preservation Districts, and lands whose development rights have been sold to preserve them for farming (PDRs).		N/A



Item #	Required Information [per §234-22A(7)]	In Compliance	Not in Compliance
24.	Existing streets, watercourses, floodplains, wetlands or other environmentally sensitive areas on and within 200 feet of site.	X	
25.*	Location of all wetlands and supporting documentation.		N/A
26.	Location of 100-year floodplain based on current Flood Insurance Rate Map (FIRM).		N/A
27.	Water-resource protection areas.		N/A
28.	Existing right-of-way and/or easements on and within 200 feet of site.	X	
29.	Topographical features of the site from the USC&GS Map.	X	
30.	Existing and proposed contour intervals based on USC&GS data at 1-foot intervals; contours shall extend at least 200 feet beyond subject property.	X	
31.	Boundary limits, nature and extent of wooded areas, specimen trees, and other significant features.	X	
32.	Existing drainage system of site and of any larger tract or basin of which it is a part.	X	
33.	Drainage Area Map.		Previously Submitted*
34.	Drainage calculations.		Previously Submitted*
Improvements and Construction Information			
35.	Water supply and distribution plan.		X*
36.	Sewage collection and treatment plan.		X*
37.*	Soil erosion and sediment control plan.	X	
38.*	Grading plan.	X	
39.*	Permanent stormwater management plan.	X	
40.	Additional utility infrastructure plans, including gas, telephone, electric, cable TV.		Providing at Final
41.	Open space and recreation plan.		N/A
42.	Detailed lighting plan.		Providing at Final
43.	Detailed landscaping plan.		Providing at Final
44.	Site identification signs, traffic control signs, and directional signs.		X*
45.	Sight triangles.	X	
46.	Vehicular and pedestrian circulation patterns.	X	
47.	Parking and loading plan showing spaces, size, type, aisle width, curb cuts, drives, driveways, and all ingress and egress areas and dimensions.	X	
48.	Spot and finished elevations at all property corners, corners of all structures or dwellings, existing or proposed first floor elevations.		Providing at Final
49.	Construction details, such as cross sections and profiles, as required by applicable laws, regulations, and policies.		Providing at Final
50.	Proposed street names.		N/A
51.	New blocks lettered consecutively; lots numbered in consecutive numerical order.		N/A
52.	Other information required by Town of Bridgeville, Sussex County, or other departments and agencies involved in plan approval.		Providing at Final



In Compliance

Not in Compliance due to missing information as stated in the Not in Compliance column above and any additional information noted below:

8. Maximum building coverage (70%) and proposed not listed in schedule.

33/34. Drainage area map and calculations were previously submitted; however, confirmation is needed that these have been revised as needed to address the updated site layout and change to stormwater basin area/depth.

35. Revised plans do not show the water connections. Final plans will need to provide these for the revised layout.

36. Revised plans do not show sewage connections. Final plans will need to provide these for the revised layout.

44. Site identification signage not indicated; can be provided with final plans or with Building Permit.

Applicant is also deferring a number of requirements to Final Development Plan review (indicated by “Providing at Final”).

Application Reviewed by: Lauren Good, AICP, Project Manager Date: 2022-06-15

QA/QC: Darren O’Neill, PE, Contract Manager Date: 2022-06-16