



May 5, 2014

**REVISED APPROVAL**

Mr. Casey Rauch  
Rauch, Inc.  
110 North Washington Street  
Easton, MD 21601

Town of Bridgeville  
PWS #DE0000559  
Approval #06W238 REV 1

Re: Heritage Shores- Phase 3A

Dear Mr. Rauch:

The Division of Public Health Office of Engineering has reviewed the revised water distribution plans for Heritage Shores Phase 3A submitted by Rauch, Inc. The plans consist of:

1. Application for Construction of New or Existing Public Water System dated May 2, 2014.
2. Two copies of the plans entitled "Heritage Shores- Phase 3A" dated March 18, 2014 and revised April 17, 2014.

These plans will replace the previous plans, Approval to Construct # 06W238. The Approval to Construct number, 06W238 and conditions dated October 26, 2006 will remain the same. The approval is void if construction has not been started by May 5, 2015. Thank you for bringing the changes to our attention.

Maintain the minimum 18 inch vertical separation between the proposed 6 inch fire main and the sanitary sewer where they cross on Street 3C on sheet WS-2, profiles on sheet WS-4. One set of as-built drawings, including profile markups, must be submitted with satisfactory bacteriological results before an Approval to Operate will be issued.

I am sending one set of plans with a copy of this approval to Rauch, Inc. that is signed and dated by the Office of Engineering. Please do not hesitate to contact me at (302) 741-8646 with questions or concerns.

Sincerely,

A handwritten signature in blue ink that reads "William J. Milliken, Jr.".

William J. Milliken, Jr.  
Engineer III  
Office of Engineering

Cc: Scott Kimball, Town of Bridgeville