

# WATER DEPARTMENT

## NOVEMBER 2022 MONTHLY REPORT

WATER SUPPLIED FOR THE MONTH  
AVERAGE DAILY WATER SUPPLIED

6,767,400 gallons  
226,000 gallons

WATER INSPECTIONS/COS  
12

METERS INSTALLED  
NEW REPLACEMENTS  
14 34


FINAL READINGS  
4

SHUT OFFS  
21

WORK ORDERS  
2

1. Water meter readings
2. Routine daily samples and readings at wells
3. Monthly water samples and reports for ODW
4. Performed routine duties and regular maintenance
5. Flushed fire hydrants
6. Did various Miss Utility locates
7. Having fire hydrants painted

Brandon Slater



Water Department

Superintendent

DE OPERATOR #7

101 North Main Street, Bridgeville, Delaware 19933  
Ph (302) 337-7135 Fax (302) 337-7817  
[townofbridgeville@gmail.com](mailto:townofbridgeville@gmail.com)  
[www.bridgeville.delaware.gov](http://www.bridgeville.delaware.gov)