From: <u>McCall, Desiree (FireMarshal)</u>

To: <u>ken@axeng.com</u>

Subject: RE: 0579-2201 Pods of Bridgeville

Date: Wednesday, December 14, 2022 8:14:27 AM

I have no objection to this. The plans will remain "approved as submitted" in our system.

From: ken@axeng.com <ken@axeng.com>
Sent: Tuesday, December 13, 2022 3:44 PM

To: McCall, Desiree (FireMarshal) < Desiree.McCall@delaware.gov>

Subject: 0579-2201 Pods of Bridgeville

Desiree,

Our Site Plan is nearing final approval. I believe that there are no changes relevant to your review and approval.

The attached cover letter to the Town of Bridgeville indicates that the project has the following status indicated:

_

Office of the State Fire Marshal

1. Approval issued June 16, 2022 - Plan Review Number 2022-04-210465-MJS-02

There are no changes on sheets C-4 and C-5 to the fire lanes, water distribution system and fire hydrant placement since this approval was issued. The Town Engineer requested the addition of a back-flow preventer, and that the hydrant be tapped directly into the existing 12" main instead of the 6" fire line extending to the building.

If you have no objection to this change, can you respond to this e-mail indicating that to be the case.

Thank you,

Ken

Kenneth R. Christenbury, P.E. President, Axiom Engineering, LLC 18 Chestnut Street Georgetown, DE 19947 Answering Service(302) 855-0810 Office 302-858-4466 Fax 855-0812

ken@axeng.com www.axeng.com



18 Chestnut Street Georgetown, DE 19947 Phone: 302.855.0810

Fax: 302.855.0812 E-mail: ken@axeng.com www.axeng.com

Kenneth R. Christenbury, P.E.
President