



# WATER DEPARTMENT

## DECEMBER 2022 MONTHLY REPORT

WATER SUPPLIED FOR THE MONTH  
AVERAGE DAILY WATER SUPPLIED

6,842,400 gallons  
221,000 gallons

WATER INSPECTIONS/COS  
9

METERS INSTALLED  
NEW REPLACEMENTS  
14 34

FINAL READINGS  
4

SHUT OFFS  
0

WORK ORDERS  
24

1. Water meter readings
2. Routine daily samples and readings at wells
3. Monthly water samples and reports for ODW
4. Performed routine duties and regular maintenance
5. Flushed fire hydrants
6. Did various Miss Utility locates
7. Having fire hydrants painted

Brandon Slater

Water Department

Superintendent

DE OPERATOR #7

101 North Main Street, Bridgeville, Delaware 19933

Ph (302) 337-7135 Fax (302) 337-7817

[townofbridgeville@gmail.com](mailto:townofbridgeville@gmail.com)

[www.bridgeville.delaware.gov](http://www.bridgeville.delaware.gov)